



Chino Valley Fire District

14011 City Center Drive
Chino Hills, CA 91709
(909) 902-5260 Administration
(909) 902-5250 Fax
Chinovalleyfire.org

Board of Directors

Mike Kreeger
President
Tom Haughey
Vice President
Harvey Luth
Sarah Ramos-
Evinger
Andrew Romaine

Fire Chief
Dave Williams

April 15, 2026

2024-00001783

EDM RECYCLING - ANA SALAZAR
13975 MONTE VISTA AVE
CHINO, CA - California 91710

Project Name: EDM RECYCLING - PL24-0086
Project Address: 13975 MONTE VISTA AVE
CHINO, CA 91710

It is a recommendation of the Fire District that the developer of every new construction project facilitate a preconstruction meeting. The meeting is to be scheduled with the Fire District Inspector for said project.

The following are the conditions of the above referenced permit/project. All conditions shall be adhered to, failure to comply with said conditions may result in the revocation of said permit and/or punitive fines as outlined in the Fire District fee schedule.

We look forward to a cooperative working relationship throughout the project. Should you have any questions regarding the project, including the conditions as set forth herein, please feel free to contact our office at (909) 902-5280.

Fire Protection Requirements

- 3.1 High-Piled Combustible Storage plans and permit required for storage of combustible materials in closely packed piles, on pallets, in racks, or on shelves where the top of storage is greater than 12 feet in height. High-piled combustible storage also includes certain high-hazard commodities, such as rubber tires, Group A plastics, flammable and combustible liquids, idle pallets, and similar commodities where the top of storage is greater than 6 feet in height. CFC 3202
Update current HPS plan
- 3.2 Hand-held portable fire extinguishers are required to be installed. The location, type and cabinet design shall be approved by the Community Risk Reduction Division.
- 3.3 Exits, doors, signs and approved path marking shall be installed in accordance with the current adopted edition of the California Building Code, Section 1007

3.4 An electronic/PDF set of plans shall be submitted separately for each of the following listed items to the Fire District for review, approval and permit prior to any installation or work being done. Approved plans must be maintained at the worksite during construction. Fees are due at the time of submittal.

a) High Piled Combustible Storage

Applicable Standards:

NONE

CVFD Standards available online at <http://www.chinovalleyfire.org>